



# Cement Mill Test Report

Month of Issue: August 2023

**Plant:** Harleyville, South Carolina  
**Product:** Stucco Cement  
**Silo:** Bag  
**Manufactured:** July 2023

## ASTM C1328 Standard Requirements

Item	Spec limit	Test Result
Fineness, Residue retained on a 45 um sieve (%)	24 max	2
Time of setting, Gillmore method: Initial set, (minutes)	90 min 1000 max	180
Compressive strength (MPa, [PSI]) 7 days	12.4 [1800]	19.0 [2760]
28 days (Reflects previous month's data)	20.0 [2900]	26.2 [3800]
Air content of mortar (%)	8 min 20 max	13
Water Retention (% of original flow)	70 min	83

Analysts: Richard Buford, George Wren, Neil Graham

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C1328.

**Argos USA**  
Harleyville Plant  
463 Judge Street, Harleyville, South Carolina 29448  
Phone: 843-806-2244

Certified By:

**Sean J. Makens - Quality Manager**  
Report created: 8/8/2023