



Cement Mill Test Report

Month of Issue: November 2023

Plant: Harleyville, South Carolina
Product: Stucco Cement
Silo: Bag
Manufactured: July 2023

ASTM C1328 Standard Requirements

Item	Spec limit	Test Result
Fineness, Residue retained on a 45 um sieve (%)	24 max	2
Time of setting, Gillmore method: Initial set, (minutes)	90 min 1000 max	180
Compressive strength (MPa, [PSI]) 7 days	12.4 [1800]	19.0 [2760]
28 days (Reflects previous month's data)	20.0 [2900]	23.7 [3440]
Air content of mortar (%)	8 min 20 max	13
Water Retention (% of original flow)	70 min	85

Analysts: Richard Buford, George Wren, Neil Graham

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C1328.

Argos USA
Harleyville Plant
463 Judge Street, Harleyville, South Carolina 29448
Phone: 843-806-2244

Certified By:

Sean J. Makens - Quality Manager
Report created: 11/2/2023