



Cement Mill Test Report

Month of Issue: November 2022

Plant: Harleyville, South Carolina
Product: Stucco Cement
Silo: Bag
Manufactured: October 2022

ASTM C1328 Standard Requirements

Item	Spec limit	Test Result
Fineness, Residue retained on a 45 um sieve (%)	24 max	2
Autoclave expansion (%)	1.0 max	-0.01
Time of setting, Gillmore method: Initial set, minutes	90 min 1000 max	200
Compressive strength (MPa, [PSI]) 7 days	12.4 (1800)	20.1 [2910]
28 days (Reflects previous month's data)	20.0 (2900)	28.7 [4150]
Air content of mortar (%)	8 min 20 max	14
Water Retention (% of original flow)	70 min	85

Analysts: Robert Parker, Richard Buford, George Wren.

We certify that the above described cement, at the time of shipment, meets the requirements of ASTM C1328.

Argos USA
Harleyville Plant
463 Judge Street, Harleyville, South Carolina 29448
Phone: 843-462-7651

Certified By:

Sean J. Makens - Quality Manager
Report created: 11/14/2022